



城東抽水所No.6雨水ポンプ設備工事

1 設計図書の一部に表記誤りがありました。下記正誤表をご確認ください。

訂正箇所	誤	正																								
<p>特記仕様書 P21 第29条 鋼製品類 1 鋼製品類仕様及び施工範囲</p>	<table border="1"> <thead> <tr> <th>名称</th> <th>設置場所</th> <th>材質</th> <th>備考</th> </tr> </thead> <tbody> <tr> <td>No.4,5雨水ポンプ上部開口部床板</td> <td>ポンプ棟</td> <td>SS400+Zn</td> <td></td> </tr> <tr> <td>No.4,5給水ポンプ架台</td> <td>ポンプ棟</td> <td>SS400+Zn</td> <td></td> </tr> </tbody> </table>	名称	設置場所	材質	備考	No.4,5雨水ポンプ上部開口部床板	ポンプ棟	SS400+Zn		No.4,5給水ポンプ架台	ポンプ棟	SS400+Zn		<table border="1"> <thead> <tr> <th>名称</th> <th>設置場所</th> <th>材質</th> <th>備考</th> </tr> </thead> <tbody> <tr> <td>給水管支持具</td> <td>ポンプ棟</td> <td>SS400+Zn</td> <td></td> </tr> <tr> <td>鉄蓋</td> <td>ポンプ棟</td> <td>CHPL</td> <td>排水溝用</td> </tr> </tbody> </table>	名称	設置場所	材質	備考	給水管支持具	ポンプ棟	SS400+Zn		鉄蓋	ポンプ棟	CHPL	排水溝用
名称	設置場所	材質	備考																							
No.4,5雨水ポンプ上部開口部床板	ポンプ棟	SS400+Zn																								
No.4,5給水ポンプ架台	ポンプ棟	SS400+Zn																								
名称	設置場所	材質	備考																							
給水管支持具	ポンプ棟	SS400+Zn																								
鉄蓋	ポンプ棟	CHPL	排水溝用																							
<p>図面全葉36内8号</p>	 <p>Architectural drawing of the No. 4, 5 water pump building. The drawing shows a floor plan with a red rectangular area highlighted, indicating the location of the original incorrect specification. The drawing includes grid lines A, B, and C, and a scale of 1/100.</p>	 <p>Architectural drawing of the No. 4, 5 water pump building. The drawing shows a floor plan with a red rectangular area highlighted, indicating the location of the corrected specification. The drawing includes grid lines A, B, and C, and a scale of 1/100.</p>																								