

令和7年8月22日公告

大阪市役所本庁舎照明設備改修工事

○設計図面に修正がありました。下記正誤表をご確認ください。

修正箇所	誤	正
設計図面 No.10図	別紙（１）のとおり	別紙（２）のとおり

照明器具数表

記号	形状	ランプ	合計	B 4 階	M B 4 階	B 3 階	B 2 階	B 1 階	1 階	2 階	3 階	3 階天井	4 階	5 階	6 階	7 階	8 階	P 1 階	P 2 階	P 2 階天井	P 3 階
A21	器具設置	HF50Wx1	4					1													
A22	器具設置	HF50Wx1	1		2			2													
A2D	器具設置	HF100x2 ミニ球	4			1	1	2													
A321	器具設置	HF50Wx1	7																		
A322	器具設置	HF50Wx1	4																		
A322-2	器具設置	HF50Wx2	6					6													
A322-3	器具設置	HF50Wx3	1					1													
A41	器具設置	HF50Wx1	15			4	4	6													
A41-2	器具設置	HF50Wx2	2					2													
A42	器具設置	HF50Wx2	170			6	11	78	3	5	5		12	21	10	9	3	7			
A42-2	器具設置	HF50Wx2	3			1			1					1							
A42-3	器具設置	HF50Wx3	1																		
A42-4	器具設置	HF50Wx4	1						1												
A42 (FL400)	器具設置	FL400x1	8				4	1													
A42 (No)	器具設置	HF50Wx2	14							5				9			3				
A42D	器具設置	HF50Wx2 ミニ球	188			3	7	8	60	8	6	6		15	22	12	11				
A42D (FL400)	器具設置	FL400x2 ミニ球	5					2	1												
A42-2 D-1	器具設置	HF50Wx2 ミニ球	9					2	2	2				2	1						
A42-2 (FL400) D-1	器具設置	FL400x2 ミニ球	12																		
A42-4 D-1	器具設置	HF50Wx4 ミニ球	1				1	9	1					1							
A42-4 D-1	器具設置	HF50Wx4 ミニ球	1																		
A42-4 D-2	器具設置	HF50Wx4 ミニ球x2	24					2	2	4	4			6		4	2				
A42-5 D-1	器具設置	HF50Wx5 ミニ球	6					6													
A42-5 D-2	器具設置	HF50Wx5 ミニ球x2	3					2	1												
A42-6 D-2	器具設置	HF50Wx6 ミニ球x2	3					2	1												
A42-7 D-2	器具設置	HF50Wx7 ミニ球x2	3					1													
A42 (センサー付)	器具設置	HF50Wx2 センサー付	3					3													
A43	器具設置	HF50Wx2	26					2	2												
A43	器具設置	HF50Wx2 ミニ球x2	3		2	1	3	3	3	2	3	3		3	2	3	3	2	2	1	
B4D-6	器具設置	HF50Wx4	3																		
B4D-6 IL	器具設置	HF50Wx4 電球x1	1																		
C322	器具設置	FL400x2	5					5													
C42 (FL400)-2	器具設置	FL400x2	1								1										
C42 (FL400)-3	器具設置	FL400x3	5									5									
D42-1 IL D-3	器具設置	HF50Wx2 IL ミニ球x3	10						10												
D42-4 IL-1	システム支持用器具	HF50Wx4 非常用照灯x1	2							2											
D42-7 IL-3	システム支持用器具	HF50Wx7 非常用照灯x3	1								1										
D42-8 IL-2	システム支持用器具	HF50Wx8 非常用照灯x2	1								1										
D42-9	システム支持用器具	HF50Wx9	2									2									
D42-9 IL-2	システム支持用器具	HF50Wx9 非常用照灯x2	2							2											
F22	器具設置	FL50Wx2	7																	1	
F22D	器具設置	FL50Wx2 ミニ球	2			1													2		2
F322	器具設置	HF50Wx2	2																		
F41	器具設置	HF50Wx1	103		55	32			6	6								1			
F41P	器具設置	HF50Wx1	107																		
F41 (FL400)	器具設置	FL400x1	7												2	2	3				
F41 (センサー付)	器具設置	HF50Wx1 センサー付	9					9													
F41P (センサー付)	器具設置	HF50Wx1 センサー付	1																		
F41D	器具設置	HF50Wx1 ミニ球	1																		1
F41D (センサー付)	器具設置	HF50Wx1 ミニ球 センサー付	4		4																
F41D (センサー付)	器具設置	HF50Wx1 ミニ球 センサー付	16					16													
F41DP (センサー付)	器具設置	HF50Wx1 ミニ球 センサー付	1					1													
F42	器具設置	HF50Wx2	112		62	26	15	2			1	1			4						
F42 (FL400)	器具設置	FL400x2	1																		
F42 (合計)	器具設置	HF50Wx2	2		1																
F42 (センサー付)	器具設置	HF50Wx2	22		22																
F42D	器具設置	HF50Wx2 ミニ球	74		34	29	3	2		2	2		1								
F42D (FL400)	器具設置	HF50Wx2 ミニ球	10		10																
F42D (センサー付)	器具設置	HF50Wx2 ミニ球	3																		
F42D (センサー付)	器具設置	FL400x2 ミニ球	3																		
F42D (センサー付)	器具設置	HF50Wx2 センサー付	2																		
F42D (センサー付)	器具設置	HF50Wx2	17																		
F42D (センサー付)	器具設置	HF50Wx2	2																		
F42D (センサー付)	器具設置	HF50Wx2	26					26													
F42D (センサー付)	器具設置	HF50Wx2	6		6																
G41P	器具設置	FL400x1	6		4			2													
G42P	器具設置	FL400x2	5		4			1													
H322	器具設置	HF50Wx2	1																		
K22	器具設置	HF50Wx2	1																		
K22D (FL200)	器具設置	FL200x2 ミニ球	2																		
K41	器具設置	FL400x1	301		198	3	91	5		1	2										1
K41 (FL400)	器具設置	FL400x1	1																		
K41 (合計)	器具設置	HF50Wx1	142		42	100															
K41 (センサー付)	器具設置	HF50Wx1	799		151	2	266	219	12	9	7	4									17
K41 (FL400) (センサー付)	器具設置	FL400x1	16																		
K41 (センサー付)	器具設置	HF50Wx1 センサー付	1		1																
K41 (センサー付)	器具設置	HF50Wx1 センサー付	11		11																
K41D	器具設置	HF50Wx1 ミニ球	5				2	2													
K41D (センサー付)	器具設置	HF50Wx1 ミニ球	155		1		91	44													
K41D (センサー付)	器具設置	HF50Wx1 ミニ球 センサー付	13		13																
K42	器具設置	HF50Wx2	44		1																
K42 (センサー付)	器具設置	HF50Wx2	127		50		19	26	2	2	2	2		2	2	2	2	4	8		4
K42D	器具設置	HF50Wx2 ミニ球	34		2			31	1												
K42D (センサー付)	器具設置	HF50Wx2 ミニ球	125		52		6	22	2	4	3	3		3	3	3	3	3	7		8
K42D (FL400) (センサー付)	器具設置	FL400x2 ミニ球	1					1													
L210	器具設置	HF50Wx1 ミニ球	1						1												
L22D-1	器具設置	HF50Wx1 ミニ球	5																		
L22D-2	器具設置	HF50Wx1 ミニ球	2																		
L42D-1	器具設置	HF50Wx1 ミニ球x2	80				6	4	4	7	7	14	6	4	6	6	6	8	2		
L42D-2	器具設置	HF50Wx1 ミニ球x2	72		4		2	4	8	7	5	6	6	6	6	6	4	2			
M42 (FL400)	器具設置	FL400x2	4																		
M42D (FL400)	器具設置	FL400x2 ミニ球	2																		
N11	器具設置	FL50Wx1	7			1			2												
N21	器具設置	FL50Wx1	1						3												
P10	器具設置	FL100Wx1	31						4												
S41	器具設置	FL50Wx1	97		31	5	14	8	2	1	1	1		6	4	6	6	6	5	1	1
S41 (FL400)	器具設置	FL400x1	2																		
S41 (センサー付)	器具設置	HF50Wx1	3		3																
T21	器具設置	FL50Wx1	3					1													
T21c (FL200)	器具設置	FL200x1	16																		
T31	器具設置	HF50Wx1	103						16												
T31c	器具設置	HF50Wx1	103																		
T41	器具設置	HF50Wx1	43			2		3	2	2	4	2									

照明器具数量表

[illegible]

照明器具数量表

[illegible]

埋込スイッチ数量表

注記) . 取付棒及びプレートは再使用

品名		連配・取付特及びプレートは不使用																		
記号	仕様	合計	3層	M3x4	B3層	B2層	B1層	1層	2層	3層	3層x非用	4層	6層	6層	7層	8層	P1層	P2層	2層x非用	P3層
●	1P15Ax1	53		54	62	46	48	31	29	29		24	31	21	21	19	3			5
●	2P15Ax1	60	10	8	2			5	5	2	2		4	2	4	1	11	2	1	1
●	3P15Ax1	43				1														
●	3P15Ax1	2	5	4	3	9	2					2	2	2	2	4	6	1		
●	4W15Ax1	2									2									
●	1P15Ax1	56	8	10	6	6	12	1				1	2	2		2	4	3		1
●	1P15Ax1	2P15Ax1										2	2			1	2			
●	1P15Ax1	2P15Ax1(7-35x4)	1	1																
●	1P15Ax1	3W15Ax1	2				1						1							
●	2P15Ax2	5	1	1													3			
●	3W15Ax2	9	4	1					2			1					1			
●	4W15Ax2																			
●	1P15Ax1	PLx1(電圧)	18	3		2	3	4	1				1		1	1		1		1
●	2P15Ax1	PLx1(電圧)	8							1	1		2	1	2	1				
●	1P15Ax3	6	3				2													1
●	1P15Ax2	3W15Ax1	1												1					
●	1P15Ax1	3W15Ax2	4				2						2							
●	3W15Ax2	2P15Ax1	1	1																
●	3W15Ax3																2			
●	1P15Ax2	PLx1	5																1	
●	1P15Ax4	5	2																	
●	1P15Ax3	2P15Ax1	1	1															2	1
●	1P15Ax2	2P15Ax2	2														2			
●	1P15Ax1	3W15Ax2	1	1																
●	3W15Ax3	PLx1(電圧)	3																	
●	1P15Ax6	3	1													1				
●	3W15Ax6	2					2													
●	2P15Ax8	1																1		
●	2P15Ax10	1	1																	
●	2P15Ax1	1W	2																	
●	合計	780	114	80	77	58	88	40	34	31	6	32	44	31	32	48	35	18	1	11

隋高表 (参考)

規格		
PH3F	～ 屋上	4 070 mm
PH2F	～ PH3F	5 050 mm
PH1F	～ PH2F	4 450 mm
8F	～ PH1F	4 400 mm
2F	～ 8F (各階)	4 100 mm
1F	～ 2F	5 500 mm
B1F	～ 1F	4 300 mm
B2F	～ B1F	4 150 mm
B3F	～ B2F	4 050 mm
MB4F	～ B3F	3 300 mm
R4F	～ MB4F	2 720 mm

※寸法は参考値とする

工事名称	大阪市役所本庁舎照明設備改修工事		令和 6 年度
図面名称	照明器具数量表・埋込スイッチ数量表		図面付(枚) : A 1
縮 尺	一	図面番号	No. 10 (49 枚の内)
大 阪 市 都 市 整 備 局 企 画 部 施 設 整 備 課	設計 担当者 氏 名	株式会社 UR1ンケー 西日本支社	